

**Consultancy & Research Section**

**Material Compliance Report (MCR) 4019/2020**  
(For Ministry of Works projects)

<b>Material Detail:</b>	<i>External Thermal Insulation System with model(s)/type(s): Terraco EIFS - Alpha System</i>
<b>Manufacturer:</b>	<i>Terraco UAE Ltd. Co. (UNITED ARAB EMIRATES)</i>
<b>Applicant:</b>	<i>Green Innova Trading P.O. Box 18644, Bldg. 850, Road 425, Block 404, Sanabis, Manama, Kingdom of Bahrain</i>

Following MED standard procedures for assessment and technical evaluations of the above Material, as to compliance with the Ministry of Works' specifications and requirements, we advise as per the following details:

**i. Compliance with Relevant Standards & Specifications**

✓	Acceptable
---	------------

**ii. Adequacy for use in Ministry of Works projects**

✓	Adequate. The Material is suitable for use in Ministry of Works' projects.
---	---

**iii. Comments**

- The Product when tested should adhere to **ASTM C578, ASTM E84, EIMA 99-A & European Guidelines - ETAG 004 & ETAG 014 requirements for ETICS/EIFS** and shall always conform to the Standard Specifications for Construction Works - 2019 of the MOW projects.
- This compliance report does in no way relieve the supplier or contractor of their obligation with respect to obtaining the necessary approval of the concerned Project Engineer for a specific project.
- The material will be subject to factory inspection and periodic quality control assessment by the Materials Engineering Directorate personnel.

**Note:**

*This Report is valid for maximum of 1 year(s) from the date of this Report unless otherwise stated or there is a change / revision in the material technical specifications, manufacturing process or relevant Standards & Specifications requirements.*

Signed & stamped by,

Date: 14 December 2020

MAS File 4752/AMCG



Director, Materials Engineering Directorate